



NOTES:

1. APPROVED CASING SPACERS SHALL BE USED AND INSTALLED AS PER THE MANUFACTURERS RECOMMENDED PROCEDURE. SPACERS SHALL BE SIZED TO PREVENT FLOATING.
2. STEEL CASING PIPE TO BE CATHODICALLY PROTECTED AT BOTH ENDS. (14.5 kg MAGNESIUM ANODE)
3. STEEL CASING PIPE TO CONFORM TO REQUIREMENTS OF GRADE 2 STEEL AS SPECIFIED IN ASTM STANDARD A252, CSA Z662 AND OPSS 1802. PIPE ENDS SHALL BE BEVEL EDGED ON THE OUTSIDE TO AN ANGLE OF 30° FOR BUTT WELD SPLICING.
4. ALL WATERMAIN JOINTS WITHIN STEEL CASING PIPE TO BE RESTRAINED.
5. BOTH ENDS TO BE CAPPED BETWEEN THE CASING & HOST PIPES TO PREVENT SEDIMENT MIGRATION INSIDE THE CASING PIPE.

PETERBOROUGH UTILITIES COMMISSION

TITLE		REVISION		DATE
RECOMMENDED METHOD OF SUPPORT FOR WATERMAIN IN CASING PIPE		No.		
		1.	REVISE NOTES / REMOVE CHART	29 APR, 2009
DRAWN BY	<i>Steve Billing</i>	SCALE	NOT TO SCALE	
DESIGNED	<i>Cheryl Argue</i>	JOB COST		
APPROVED	<i>[Signature]</i>	DATE	25 OCT, 2018	
			DRAWING No.	CADD A1997