



## NOTES

- 1) Contractor shall use proper mould and cartridges for the cadweld. (configuration of mould varies with pipe diameter)
- 2) The pipe surface at the point of weld must be scraped clean of bituminous coating to provide a good clean contact.
- 3) After the weld is completed, a thick coating of T.C. Mastic (Tapecoat of Canada) must be applied, by brush, to all exposed metal at the weld.
- 4) Packaged magnesium anode specifications are in approved material list and shall be spaced in accordance with P.U.C. specifications.

# PETERBOROUGH UTILITIES SERVICES INCORPORATED

TITLE DETAIL FOR CONNECTING ANODES TO DUCTILE IRON WATERMAINS		No.	REVISION	DATE
		1.		
DRAWN BY <i>Steve Billings</i>	SCALE NOT TO SCALE	2.		
DESIGNED <i>[Signature]</i>	JOB COST	DRAWING No.		
APPROVED <i>[Signature]</i>	DATE APRIL 19, 2011	CADD <b>A2370</b>		