



NOTE

- 1) CONCRETE ENCASED STEEL MAINS SHALL BE SUPPORTED WITH CONCRETE TO UNDERSIDE OF MAIN. TAR PAPER IS TO BE USED BETWEEN THE TWO CONCRETE SURFACES.

PETERBOROUGH UTILITIES SERVICES INCORPORATED

TITLE		No.	REVISION	DATE
TYPICAL DETAIL FOR SUPPORTING WATERMAIN PIPE LARGER THAN 300mm DIAMETER		1.		
		2.		
DRAWN BY	SCALE	DRAWING No.		
DESIGNED	JOB COST	CADD A2373		
APPROVED	DATE			