



NOTES

- 1) Rigid polyurethane foam half shells shall be used.
For approved manufacturers, refer to PUSI material specifications
- 2) All insulating material must be installed according to manufacturers specifications.
- 3) Unless otherwise approved by the Engineer, insulation shall be a minimum of 50mm thick.

PETERBOROUGH UTILITIES SERVICES INCORPORATED

TITLE		No.	REVISION	DATE
HALF SHELL INSULATION OF WATERMAIN PIPE		1.		
		2.		
DRAWN BY	Scott Langill	SCALE		NOT TO SCALE
DESIGNED	<i>Cheryl Sturges COT</i>	JOB COST		DRAWING No. CADD A3006
APPROVED	<i>[Signature]</i>	DATE	February 18, 2015	