


NOTES

- 1) RIGID POLYURETHANE FOAM HALF SHELLS SHALL BE USED. FOR APPROVED PRODUCTS REFER TO PUC APPROVED MANUFACTURERS LIST. www.peterboroughutilities.ca
- 2) ALL INSULATING MATERIAL MUST BE INSTALLED ACCORDING TO MANUFACTURER'S SPECIFICATIONS.
- 3) UNLESS OTHERWISE APPROVED BY THE ENGINEER, INSULATION SHALL BE A MINIMUM OF 50mm THICK.

PETERBOROUGH UTILITIES COMMISSION
STANDARD WATERWORKS DRAWING

	TITLE	No.	REVISION	DATE
	HALF SHELL INSULATION	1.	UPDATED TITLE BLOCK	11-03-2023
		2.		
DRAWN BY: S. LANGILL	APPROVED: G. CRAIG	A3006		
DESIGNED: C. ARGUE	DATE: 02-18-2015			